

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 2620-1153:100 Page 1 of 1

**CATEGORY:** Wallcovering (Interior)

**LISTEE:** Charles G. Hardy, Inc., 15723 Vermont Avenue, Paramount, CA 90723-4228  
Contact: Joseph Barloon \*(562) 634-6560 FAX (562) 790-8809

**DESIGN:** Hardy vinyl-covered tackboard, Gen-tex cloth scrim backed vinyl on wood fiberboard wall panel system. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** Flame Spread 80  
Smoke Density 295

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product designation, and CSFM label on package.

**APPROVAL:** Listed as a Class III wall surfacing material when applied to gypsum wallboard or a plywood substrate.

\*Corrected 06-08-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**